



City of Yellowknife

OIL TANK (Above Ground) Installation Checklist

Please complete the Permit number:

PR - 20__ -

(This checklist applies to the installation of aboveground atmospheric storage and supply tanks up to an individual capacity of 2500 L (550 gal) and a maximum aggregate capacity of 5000 L (1100 gal)

For GENERAL INFORMATION, please call: 867-920-5600

Email: permits@yellowknife.ca in a PDF format.

For TECHNICAL INFORMATION please call: 867-920-5629

Delivered to: City Hall, 4807-52 Street

Mailed to: City of Yellowknife, PO Box 580, Yellowknife, NT, X1A 2N4

| I. GENERAL INFORMATION | | Preferred Communication | |
|---|--|-------------------------|--|
| Owner: _____ | | Email: _____ | |
| Contractor: _____ | | Email: _____ | |
| Business License: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> | | | |

| II. PROJECT INFORMATION | | |
|----------------------------------|--------------|-------------|
| Project Municipal Address: _____ | | |
| Legal Description - Lot: _____ | Block: _____ | Plan: _____ |

| III. TANK AND INSTALLATION INFORMATION | |
|--|----------------------|
| Type of tank (i.e. ULC-S601): _____ | |
| Manufacturer: _____ | Serial number: _____ |

| CAN/CSA B139-09 ITEM | CLAUSE | YES | NO | N/A |
|--|--------------|-----|----|-----|
| 1. Support, installation, foundations and anchorage conforms to: | 7.3 | | | |
| a. The tank is installed in accordance with the manufacturer's instructions: | 7.3.2. | | | |
| b. A bottom outlet tank is pitched towards the outlet: | 7.3.10.(c) | | | |
| 2. An indoor tank conforms to: | 7.4 | | | |
| a. The tank can be installed and removed as a unit: | 7.4.3. | | | |
| b. The tank is located in conformance to temperature and spatial requirements: | 7.4.8.(a)(b) | | | |
| c. Where the horizontal distance is impracticable the reduced clearance meet: | 7.4.9.(a)(b) | | | |
| 3. An outdoor tank conforms to: | 7.5 | | | |
| a. Single storage tank conforms to spatial requirements: | 7.5.2.(a)(b) | | | |
| b. Single and/or multiple tanks conform to protection requirements: | 7.5.6 | | | |
| 4. Multiple bottom-connected tanks conform to: | 7.6 | | | |
| 5. The tank fill pipes, openings and fittings conforms to: | 7.8 | | | |
| 6. The venting conforms to: | 7.9 | | | |
| 7. The fuel level gauge conforms to: | 7.10 | | | |
| 8. Removal and disconnection of tanks conforms to: | 7.11 | | | |
| 9. The testing and commissioning of the tank conforms to: | 7.12 | | | |
| a. Fuel transferred to a replacement tank conforms to: | 7.12.4. | | | |
| 10. Piping and tubing conform to: | 9.3 | | | |
| 11. Joints and connections conform to: | 9.3.4 | | | |
| 12. Shut-off valve conforms to: | 9.4.1 | | | |
| 13. Customer was instructed to perform regular maintenance as per: | 15.2 | | | |

| IV. DECLARATION OF INSTALLER (Owner if the tank was installed by the owner) | |
|---|-------------|
| I, certify that the information submitted in this CHECKLIST is true and conforms with CAN/CSA B139-09, NBC 2010, FM-066-2010 and By-law No. 4469 to the best of my knowledge. | |
| Installer's Signature: _____ | Date: _____ |